



**Government of Jammu and Kashmir**  
**J&K e-Governance Agency**  
**Civil Secretariat, Srinagar/Jammu**  
\*\*\*\*\*

**Subject:**

1. Corrigendum Number-02 to Notification No.02 JaKeGA of 2019 dated 16-09-2019
2. Extension in date of submission of online bids in respect of Notification No.02 JaKeGA of 2019 dated 16-09-2019 regarding for Supply, Installation, Commissioning and Maintenance of WIFI Network Setup of Civil Secretariat, Jammu.

In the Notification No.02 JaKeGA of 2019 dated 16-09-2019, the Corrigendum Number-02 is issued as appended as Annexure-A to this notification.

S.No	Key Activity	Date and Time
01	Online submission of bids	20-11-2019 upto 02.00 PM
02	Submission of original instruments/ Forms as per RFP	20-11-2019 upto 02.00 PM
03	Opening of Tender	21-11-2019 at 03.00 PM

**(Bipul Pathak, IAS)**  
**Principal Secretary to Govt, IT Deptt/  
Chief Executive Officer,  
J&K e-Governance Agency**

No. JaKeGA/Gen/08/2019

Dated 11 -11-2019

**Copy to:**

1. FA/CAO, IT Department (Treasurer-JaKeGA)
2. Accounts Officer, JaKeGA.
3. Pvt. Secretary to Prpl. Secretary-ITD for information
4. Incharge website ([www.jakega.jk.gov.in](http://www.jakega.jk.gov.in)) for uploading.
5. Office file

**Annexure-A to Corrigendum issued to Notification No.02 JaKeGA of 2019 dated 16-09-2019**

S. No.	Bidder Name	Page No	Tender Specifications		Request for change	Remarks	JaKeGA corrigendum to the queries sought by the prospective bidders
		40 of 52	Technical Specifications of 25 KVA UPS with Five hours backup				
1	M/s Aman Technologies Pvt. Ltd		Capacity	25Kva Online with Five hours backup	Kindly change to 30KVA UPS	None of the reputed brands offer 25KVA UPS	Accepted. Please read as "30 KVA UPS instead of 25 KVA"
2	M/s Aman Technologies Pvt. Ltd		Input configuration	1Ph,L-N+PE	Change to 3Phase +N+PE	Change to 3 Phase as high capacity UPS does not come in Single Phase.	Accepted.
3	M/s Aman Technologies Pvt. Ltd		Programmable power management outlets	Ready from Day one	need to remove	This feature comes in entry level online UPS only.	Accepted.
4	M/s Aman Technologies Pvt. Ltd		Battery backup	Five Hours with full load and supply batteries accordingly	Two hours backup with load of 30KVA with batteries with minimum VAH 72000	5 hours backup is generally not used in these capacities and cost becomes more than 2.5 times. For five Hours with load of 30KVA batteries should be min VAH 144000	As per RFP
5	M/s Aman Technologies Pvt. Ltd		operating temperature range	0-55 deg	Request for change to 0 to 40 Deg C	This is the standard operating temperature.	Accepted
6	M/s Aman Technologies Pvt. Ltd		Noise Level	50 dBA max	Request for change to 55 dBA max	Standard for reputed brands	Accepted
7	M/s Aman Technologies Pvt. Ltd		Size	not more than 2U rack mountable	need to remove or change to UPS should be tower type	2U Rack mountable UPS not possible for asked requirement	Accepted
8	M/s Aman Technologies Pvt. Ltd	5 of 52	Bid Security and Mode of Payment		Request for waiver of EMD/Tender fee for MSME or NSIC registered organizations.		As per RFP

9	M/s Aman Technologies Pvt. Ltd	Page 9 of 52	(Point 6. Special Terms and Conditions)	<p>e. Payment Terms will be as follows subject to the successful audit report as decided by JaKeGA:</p> <p>a. 60% Payment of overall bid shall be processed at the time of delivery and subject to Bill of Material (BOM) Verification by JaKeGA and IT Department.</p> <p>b. 20% of Payment of overall bid value shall be made on Successful Installation and commissioning and completion of the project.</p> <p>c. Remaining payment shall be made quarterly in 12 equal installments after Go-Live and subject to the satisfactory functioning of the network as per scope of the project.</p>	<p>a.25% mobilization advance on submission of Bank Guarantee.</p> <p>b.55% Payment of overall bid shall be processed at the time of delivery and subject to Bill of Material (BOM) Verification by JaKeGA and IT Department.</p> <p>c.20% of Payment of overall bid value shall be made on Successful Installation and commissioning and completion of the project and on submission of 10% PBG.</p>	These are the standard payment terms for such projects.	As per RFP
10	M/s Intec Infonet Private Limited		operating temperature range	0-55 deg	0 ~ 40 °C	Above 40° C UPS capacity will de-rate Kindly amend this clause as "0-40° C".	Accepted
11	M/s Intec Infonet Private Limited		Humidity	0% to 95% non-condensing	5% ~ 95 % (no condensing)	This clause is restricting us to bid.	Accepted
12	M/s Intec Infonet Private Limited		Noise Level	50 dBA max	Should be <60dBA	Higher UPS produce noise level Min. 50 DBA and max. 60 DBA Kindly amend this clause as "Should be <60DBA".	Accepted
13	M/s Intec Infonet Private Limited		Size	not more than 2U rack mountable	Rack Mounted/ Tower UPS	This is higher rating UPS only low rating UPS are rack mountable. Kindly amend this clause as "Rack Mounted/Tower UPS".	Accepted